

## DESIGN REVIEW BOARD RECORD OF DECISION

**Meeting Date** January 28, 2016      **DRB Case No.** PDR 1517909  
**Address** 1800 Marion Drive  
**Applicant** Makayel Astoyan

### Design Review Board

DRB Member	Motion	Second	Yes	No	Absent	Abstain
Benlian			x			
Charchian		x	x			
Mardian	x		x			
Malekian			x			
Simonian			x			
<b>Total</b>			5	0		

### Design Review Board Decision: Return for Redesign.

1. Provide a grading plan.
2. Restudy the grading at the rear of the residence.
3. Restudy driveway to ensure the slope of driveway complies with the Zoning Code.
4. Rendering of the residence shall include the front retaining walls.
5. Reduce the footprint and square footage of the residence as a means to reduce the overall mass of the building and the amount of on-site grading.
6. Relocate the awning above the main entrance of the house to the first level to reduce the scale of the entryway.
7. Eliminate the swimming pool.
8. A full window schedule shall be provided. Vertical sections for typical openings shall be submitted for staff review and approval. Plans shall be amended to include operation lines for all windows. Redesign windows if making some operable affects the sightlines and overall appearance of the residence.
9. Eliminate the water feature in the front yard.
10. The design of the proposed house should relate to the styles of the other proposed residences, while allowing for individualization through massing, colors and materials, without becoming overly complex.
11. Verify power pole locations adjacent to site.
12. Show curb and gutter at area of street dedication.
13. Provide more detailed landscape drawings; include trees suitable to hillside. Also include area of street dedication.

14. Consider varying the roof heights and/or roof forms.
15. Consider a split level design to reduce massing.
16. Consider a more natural color for those areas on the residence currently proposed for the Glacier white-colored stucco.

Staff Member

Roger Kiesel

Notes:

Contact the case planner for an appointment for a DRB stamp. DRB stamps will no longer be stamped over the counter without an appointment.

The Design Review Board approves the design of project only. Approval of a project by the Design Review Board does not constitute an approval of compliance with the Zoning Code and/or Building Code requirements.

If an appeal is not filed within the 15-day appeal period of the Design Review Board decision, plans may be approved for Building Division plan check. Prior to Building Division plan check submittal, Design Review Board approved plans must be stamped approved by the Design Review staff.

Any changes to the approved plans may constitute returning to the Design Review Board for approval. Prior to Building Division plan check submittal, all changes in substantial conformance with approved plans by the Design Review Board must be on file with the Planning Division.