

# INSTALLATION REQUIREMENTS

1. ALL INSTALLATIONS MUST BE COORDINATED WITH GLENDALE WATER & POWER (GWP). ANY UNAUTHORIZED CONNECTION TO, OR OPERATION OF, A GWP FACILITY MAY BE GROUNDS FOR DENIAL OF WATER SERVICE.
2. BACKFLOW PREVENTION ASSEMBLY (BFP) MUST BE APPROVED BY THE FOUNDATION FOR CROSS-CONNECTION CONTROL AND HYDRAULIC RESEARCH AT THE UNIVERSITY OF SOUTHERN CALIFORNIA AND MUST BE INSTALLED IN THEIR ORIGINAL (UNALTERED) MANUFACTURED FORM.
3. THE ASSEMBLY SHALL BE INSTALLED AS CLOSE TO THE METER OR TO THE RIGHT-OF-WAY LINE AS PRACTICAL (SEE STANDARD DRAWING No. 6528-A & 6561-A).
4. THE BFP MUST BE TESTED BY A GWP-AUTHORIZED TESTER PRIOR TO ACTUAL SERVICE (SEE GWP'S APPROVED TESTER LIST).
5. ANY UNAUTHORIZED CONNECTION TO A BFP WILL RESULT IN DISCONNECTION OF SAID CONNECTIONS AND POSSIBLE SHUT OFF OF WATER SERVICE.
6. PLEASE CONTACT (818) 937-8948 FOR APPROVAL OF BFP INSTALLATION LOCATION PER CA CODE OF REGULATIONS, TITLE 17 & CITY OF GLENDALE ORD. No. 5678.
7. FOR A LIST OF APPROVED BFP, PLEASE CONTACT (818) 937-8948. NEW DEVICES MUST BE INSPECTED BY GWP AND TESTED BY LOS ANGELES COUNTY DEPARTMENT OF PUBLIC HEALTH CERTIFIED BACKFLOW TESTER IMMEDIATELY UPON INSTALLATION BEFORE WATER SERVICE IS APPROVED.
8. ACCORDING TO CALIFORNIA AND GLENDALE CITY CODE AND REGULATIONS, ALL COMMERCIAL FIRE SERVICES AND IRRIGATION SERVICES WILL REQUIRE SOME FORM OF BACKFLOW PREVENTION SYSTEM TO PROTECT THE POTABLE WATER SYSTEM. PLEASE BE SURE TO THOROUGHLY REVIEW GWP STANDARD DRAWINGS. (SEE STANDARD DRAWINGS 6528-A & 6561-A)
9. ALL BFP SHALL BE LOCATED AS CLOSE AS PRACTICAL TO THE USER'S CONNECTION. THEY WILL BE INSTALLED A MINIMUM OF TWELVE INCHES (12") AND NOT MORE THAN THIRTY SIX INCHES (36") ABOVE FINISHED STREET GRADE MEASURED FROM THE BOTTOM OF THE DEVICE. A MINIMUM OF TWELVE INCHES (12") SIDE CLEARANCE, AND TWENTY-FOUR INCHES (24") FRONT CLEARANCE, LOCATED WHERE IT IS READILY ACCESSIBLE FOR INSPECTION, TESTING AND MAINTENANCE.

<b>GLENDALE WATER &amp; POWER CITY OF GLENDALE CALIFORNIA</b>
<b>INSTALLATION REQUIREMENTS FOR BACKFLOW PREVENTION ASSEMBLY DEVICE (BFP)</b>

APPROVED



07/14/2015

GERALD TOM, SENIOR CIVIL ENGINEER, R.C.E. No. C51209 DATE  
GLENDALE WATER AND POWER - WATER DEPARTMENT

DES: LB  
D: GR/PN  
C:

SCALE: NONE  
DATE: 07/14/15  
APP:

SHEET No. 1 OF 1

**6762-A**